

Use this space for unexplained loss of oil & return to supervisor at once:

I BELIEVE THE OIL ADDED IS DUE TO AN UNDERGROUND LEAK

WE HAVE PERFORMED A "NO LOAD LEAK DOWN TEST" PER ANSI A17.1 RULE 1005.2B & HAVE PLACED ELEVATOR OUT OF SERVICE

UNIT FAILED A HYDOSTAIC PRESSURE TEST. ELEVATOR PLACED OUT OF SERVICE